

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 45Dated: 08.04.2026

It is certified that an inspection team headed by Sh. Rajesh
Junior engineer (Name of officer with designation) from
 PHED inspected the RAINBOW SCHOOL, Khatipura Road, Jhotwara, Jaipur on
19/03/26 (date of inspection) and on the basis of water Test Report (Attached) bearing
 no. 8910-11 dated 25/3/26 of Chief Chemist PHED Lab (PHED
 Lab) certified that the Rainbow school (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution. School also maintains the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the
 Central/State/U.T. Govt.

This certificate is valid till one year

Signature with seal:



Name

: Yashraj Kumar Singh

Designation

: Assistant Engineer

Name & Address of the Dept.

: City Sub div II (K)

Jhotwara

To,

Rainbow SchoolJNN ward no. 38Jhotwara Jaipur

(Name & Address of the institution)

सहायक अभियन्ता
 नगर उपखण्ड तृतीय (उत्तर)
 जन स्वास्थ्य अभि० विभाग
 मोटवाड़ा (जयपुर)

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2025-2026/ 8910-11

Date: The sample was not collected by this laboratory.

To,
 ✓ Director
 Rainbow School
 Khatipura Road . Jhotawara Jaipur,

Not Valid for water quality / Legal Cases

25/3/2026
 Your Letter 03 Dated 18/03/2026
 Date of Receipt 19/03/2026

Particulars			RO Water, Rainbow School Khatipura Road . Jhotawara Jaipur,
	value as per I.S.:10500/2012		
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			19/03 /2026
Date of Examination			19/03 /2026
Lab. Sample No.			P-233
1. pH	6.5-8.5	6.5-8.5	7.89
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O
5. Total Alkalinity(as CaCo3) mg/l	200	600	330
6. Total Hardness (as CaCo3) mg/l	200	600	160
7. Calcium (as Ca) mg/l	75	200	28
8. Magnesium (as Mg) mg/l	30	100	21
9. Chloride (as Cl-) mg/l	250	1000	85
10. Nitrates (as NO3-) mg/l	45	45	124
11. Sulphate(as So4-2)mg/l	200	400	22
12. Total Dissolved Solids mg/l	500	2000	755
13. Fluoride mg/l	1.00	1.5	0.22
14. Iron mg/l	1.0	No Relaxation	Nil
15. Arsenic mg/l	0.01	No Relaxation	Nil

Remark-

- 1- All chemical parameters except pH are in mg/l
- 2- Tested Results Relate only to The Samples send by you

Soni
 27/03/26
 Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2025-2026/

Date:

1- The Chief Chemist, PHED, Rajasthan, Jaipur.

Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur